



Stratus Eliminate Fuel Biocide

STRATUS ELIMINATE fuel biocide rapidly eradicates microbial growth (Diesel “bug”). Such contamination can be found in fuel, fuel storage tanks, pumps and pipework.

Recommended dosage:

1 part STRATUS ELIMINATE
to 4,000 parts fuel.

Stratus
ENERGY

Stratus Eliminate Fuel Biocide

IDENTIFYING PRESENCE OF “BUG” SYMPTOMS

- A black or brown sludge wrapped around fuel filters, resulting in regular fuel filter changes
- Strong odour from the fuel
- Poor engine performance
- Fuel discolouration

CAUSES OF MANIFESTATION

- Water present within storage tank due to condensation build-up
- Bacteria growth occurs at interface of fuel and water: slime deposit is by-product of bacteria growth
- Increased usage and content of biofuels to diesel fuels. Diesel fuel with bio content is 4 times more likely to attract ‘bug’ growth than regular diesel fuel

REMEDY

- Dosage recommendation: to achieve a complete “mix”, **STRATUS ELIMINATE** should be applied to the fuel, just prior to next delivery of fuel being discharged into tank
- Allow 24 hours for **STRATUS ELIMINATE** to take full effect
- Contaminated tanks can also transmit “bug” to vehicles and plant equipment
- Dosage may also be applied directly to vehicle/machinery storage tanks
- After treatment, provided tanks are correctly maintained and remain free of water, “bug” contamination is unlikely to recur



Stratus Energy Limited

Thornhouse Business Centre
30 Ballot Road, Irvine KA12 0HW

Tel: +44 (0)1294 276924

Fax: +44 (0)1294 275119

Email: info@stratusenergy.co.uk

www.stratusenergy.co.uk

Distributed by: